



Certificat

Certificate

Certificate of constancy of performance for products

In compliance with the Regulation 305/2011/UE of the European Parliament and of the Council of 9 March 2011.
(Construction Products Regulation or CPR)

Delivered by :

Notified Body :

AFNOR Certification

Identification number :

0333

Address :

**11 rue Francis de Pressensé
FR - 93571 LA PLAINE SAINT-DENIS CEDEX**

Delivered to :

Company:

BOUYER Industrie

Address :

**1270, avenue de Toulouse
82000 MONTAUBAN - France**

Manufacturing site(s) :

Montauban - France

Product :

**Voice alarm control and indicating equipment with power supply equipment - VULCA
VOICE**

Detailed description of product : Appendix

AFNOR Certification attests that the provisions concerning the assessment and verification of constancy of performance and the performances described in annex ZA of the standard(s), below stated, under system 1 are applied and that the product fulfills the provisions described in annex ZA of the standard(s) below designated.

Fire detection and fire alarm systems

EN 54-16:2008 - Voice alarm control and indicating equipment

EN 54-4:1997 + A1:2002 + A2:2006 - Power supply equipment

Certificate number :

0333-CPR-075536

Certificate expiry date : 9 October 2020

This certificate was first issued on 9 October 2015. Unless suspension or canceled, this certificate remains valid as long as the conditions laid down in the reference technical specifications or the manufacturing conditions in the factory or the factory production control or the product itself are not modified significantly.

Date of certificate delivery : 9 October 2015



Franck LEBEUGLE
Managing Director of AFNOR Certification

005 - 2013/05 -



Certificat

Certificate

Appendix to the certificate

Company : **BOUYER Industrie**

Certificate number : **0333-CPR-075536**

Manufacturing site(s) : **Montauban - France**

Date of certificate delivery : **9 October 2015**

Product's description :

Identification of certified product(s) (Reference)	Product designation	File number
VULCA VOICE	Voice alarm control and indicating equipment with power supply equipment	075.1801

This appendix cannot be submitted or reproduced without the document to which it is attached.

Franck LEBEUGLE
Managing Director of AFNOR Certification