

CERTIFICAT DE CONSTANCE DES PERFORMANCES

1116-CPR-159

Conformément au règlement (UE) N°305/2011 du 09/03/2011 établissant les conditions harmonisées de commercialisation pour les produits de construction (Règlement Produits de Construction – RPC), il a été établi que les produits de construction désignés ci-dessous :

SERENITY VOICE

(Elément central du système d'alarme incendie vocale (ECSAV) avec équipement d'alimentation électrique)

ELEMENT CENTRAL DU SYSTEME D'ALARME INCENDIE VOCALE (ECSAV)			
Nature de l'enveloppe :	Baie (1 seule)	Nombre maximum de zones d'alarme vocale :	1
Nombre maximum de circuits de haut-parleur :		Ligne ouverte :	6
Nombre maximum de haut-parleurs par circuit :		Ligne ouverte :	32
Composition de l'ECSAV	CS 2700 : Centrale de surveillance (1 maximum) Unité d'amplificateur (6 maximum) Carte amplificateur AA-0060 60W (6 maximum) et carte amplificateur AA-0300 280W (6 maximum)		
Fonctions optionnelles avec exigences :	Signalisation sonore, Réarmement manuel de la condition d'alarme vocale, Commande manuelle d'alarme vocale, Interface avec le dispositif de commande externe, Microphone d'urgence, Amplificateur de puissance redondant		
EQUIPEMENT D'ALIMENTATION ELECTRIQUE (EAE)			
Source d'alimentation principale	230 Vac – 50 Hz		
Source d'alimentation de secours	Carte SON 24V 6A MS 40 rack (2 batteries de 12V – 24Ah à 110Ah) Carte SON 24V 12A MS 150 rack (4 batteries de 6V – 38Ah à 225Ah ou 2 batteries de 12V – 38Ah à 225Ah)		

mis sur le marché par

BOUYER Industrie

1270, avenue de Toulouse – 82000 MONTAUBAN - France

et produits dans l'unité de fabrication

BOUYER Industrie - 1270 avenue de Toulouse - 82000 MONTAUBAN - France

font l'objet par le fabricant d'un contrôle de production en usine (CPU) et d'essais sur des échantillons prélevés dans l'unité de fabrication selon un plan d'essais pré-établi,

En sa qualité d'organisme certificateur notifié, CNPP Cert. a réalisé les essais de type initiaux pour les caractéristiques concernées du produit ainsi que l'inspection initiale de l'usine et du CPU. Il exerce la surveillance continue du CPU (évaluation et acceptation).

Ce certificat garantit que toutes les dispositions concernant l'évaluation et la vérification de la constance des performances suivant le système 1 et les caractéristiques décrites en annexe ZA des normes EN 54-16 : 2008, EN 54-4 : 1997, EN 54-4 : 1997/AC : 1999, EN 54-4 : 1997/A1 : 2002 et EN 54-4 : 1997/A2 : 2006 ont été appliquées et que les produits satisfont aux exigences requises.

Ce certificat, délivré initialement le 25/03/2022, demeure valide tant que les conditions fixées dans les spécifications techniques harmonisées citées en référence ou les conditions de production ou le CPU lui-même n'ont pas été modifiés de façon significative.

Le 25/03/2022


Christophe BODIN
Directeur CNPP Cert.

CERTIFICATE OF CONSTANCY OF PERFORMANCE

1116-CPR-159

In compliance with Regulation (EU) N°305/2011 of 09/03/2011 laying down harmonised conditions for the marketing of construction products (Construction Products Regulation – CPR), it has been stated that the construction products below:

SERENITY VOICE

(Voice Alarm Control and Indicating Equipment (V.A.C.I.E.) with integrated power supply)

VOICE ALARM CONTROL AND INDICATING EQUIPMENT (V.A.C.I.E.)			
Type of enclosure :	Rack (only 1)	Maximum number of voice alarm zones :	1
Maximum number of loudspeaker paths :		Open line :	6
Maximum number of loudspeakers by path :		Open line :	32
V.A.C.I.E. composition	CS 2700: monitoring unit (maximum 1) Amplifier unit (maximum 6) Amplifier board AA-0060 60W (maximum 6) and Amplifier board AA-0300 280W (maximum 6)		
Optional functions with requirements:	Audible indication, Manual reset of voice alarm condition, Voice alarm manual control, Interface to external control device, Emergency microphone, Redundant power amplifier		
POWER SUPPLY EQUIPMENT (PSE)			
Main power source	230 Vac – 50 Hz		
Standby power source	Board SON 24V 6A MS 40 rack (2 batteries of 12V – 24Ah to 110Ah) Board SON 24V 12A MS 150 rack (4 batteries of 6V – 38Ah to 225Ah or 2 batteries of 12V – 38Ah to 225Ah)		

placed on the market by

BOUYER Industrie

1270, avenue de Toulouse - 82000 MONTAUBAN - France

and produced in the factory

BOUYER Industrie - 1270 avenue de Toulouse - 82000 MONTAUBAN - France

are submitted by the manufacturer to a factory production control (FPC) and to further testing of samples taken at the factory in accordance with a prescribes test plan,

The approved body, CNPP Cert., has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the FPC and performs the continuous surveillance, assessment and approval of the FPC.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance according to system 1 and the characteristics described in ZA annex of the standards EN 54-16 : 2008, EN 54-4 : 1997, EN 54-4 : 1997/AC : 1999, EN 54-4 : 1997/A1 : 2002 et EN 54-4 : 1997/A2 : 2006 were applied and that the product fulfils all prescribed requirements.

This certificate was first issued on **25/03/2022** and remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.

On 25/03/2022


Christophe BODIN
Manager of CNPP Cert.